



**CEI Model GG708 HPL06Z2ST61B ($\frac{1}{16}$ " HPL Finish)
and GG708 HPL12Z2ST61B ($\frac{1}{8}$ " HPL Finish)
Perforated Air Flow Panel**

JOB OR PART NUM: 10004		REVISIONS		APPROVALS		 COMPUTER ENVIRONMENTS, INC. 1616 JOHN WEST ROAD DALLAS, TX, USA 75228 214 321 1234 FAX 214 321 2333 ceifloor.com 100% U.S. Owned 100% U.S. Made
CEI FILE NAME: GG708 PERFORATED PANEL		BY:	DATE:	ENG:	DATE:	
DRAWN BY: J THARP		BY:	DATE:	SAFETY:	DATE:	
DATE: 5 DEC 2008		BY:	DATE:	ENV:	DATE:	
SHEET: 1 OF 1	SCALE: 1 = 4	AS BUI LT:	DATE:	FI RE:	DATE:	PART OR PROJECT DESCR I PT I ON
2100 HOLES X .230 DIA = 87.25 SQUARE INCH OPEN AREA GG808 SERIES PERFORATED AIR FLOW PANEL						